



NOTES:

DESIGN:

TANK AND SUPPORT STRUCTURE SHALL BE DESIGNED, FABRICATED AND ERECTED IN ACCORDANCE WITH AWWA D100-21 AND THE PROJECT SPECIFICATIONS.

WIND LOAD: -----

SNOW LOAD: -----

SEISMIC ZONE: -----

TANK ERECTOR SHALL GROUT UNDER BASE PLATE RING.

MATERIALS:

STEEL PLATE: ASTM A36
 STRUCTURAL STEEL SHAPES: ASTM A36
 LADDER RUNGS: ASTM A706

GENERAL:

- ACCESSORIES SHOWN ON ELEVATION DRAWING ARE ROTATED FOR CLARITY.
- ALL HANDRAILS, PLATFORM LANDINGS, WALKWAYS, LADDERS, AND SAFETY CLIMB DEVICES SHALL CONFORM WITH CURRENT OSHA STANDARDS.
- SEE PROJECT SPECIFICATIONS FOR SHOP AND FIELD PAINT REQUIREMENTS.
- STERILIZE TANK IN ACCORDANCE WITH AWWA C652-92 AND PROJECT SPECIFICATIONS.
- FOR TANKS LOCATED IN REGIONS WHERE FREEZING CONDITIONS MAY OCCUR, CONSIDERATION SHALL BE MADE TO ROUTE OVERFLOW PIPE INSIDE ACCESS TUBE AND OMIT INSIDE TANK LADDER.

REV.	BY:	DATE	REMARKS		
BY:					
TITLE:					
DRAWING NO.: PEDSP-1.DWG					
DATE:					