



NOTES:

DESIGN:
 TANK AND TOWER SHALL BE DESIGNED, FABRICATED AND ERECTED IN ACCORDANCE WITH AWWA D100-21 AND PROJECT SPECIFICATIONS.

WIND LOAD: _____
 SNOW LOAD: _____
 SEISMIC ZONE: _____

MATERIALS:
 STEEL PLATE: ASTM A283 GR. C / A36
 STRUCTURAL STEEL SHAPES: ASTM A36
 LADDER RUNGS: ASTM A706

- GENERAL:**
- ACCESSORIES SHOWN ON ELEVATION DRAWING ARE ROTATED FOR CLARITY.
 - ALL HANDRAILS, LADDERS AND SAFETY CLIMB DEVICES SHALL CONFORM WITH CURRENT OSHA STANDARDS.
 - SEE PROJECT SPECIFICATIONS FOR SHOP AND FIELD PAINT REQUIREMENTS.
 - STERILIZE TANK IN ACCORDANCE WITH AWWA C652-92 AND PROJECT SPECIFICATIONS.

BY:		TITLE: ELEVATION DETAILS	
DATE:		DRAWING NO.: RES-1.DWG	
REV.	BY:	DATE	REMARKS
CALDWELL TANKS, INC. LOUISVILLE, KY. NEWNAN, GA.			