



- NOTES:**
- DESIGN:**
 TANK AND TOWER SHALL BE DESIGNED, FABRICATED AND ERECTED IN ACCORDANCE WITH AWWA D100-21 AND PROJECT SPECIFICATIONS.
- WIND LOAD:** _____
SNOW LOAD: _____
SEISMIC ZONE: _____
- MATERIALS:**
 STEEL PLATE: ASTM A36
 STRUCTURAL STEEL SHAPES: ASTM A36
 BRACE RODS AND STAY RODS: ASTM A36
 LADDER RUNGS: ASTM A706
- GENERAL:**
 - ACCESSORIES SHOWN ON ELEVATION DRAWING ARE ROTATED FOR CLARITY.
 - ALL HANDRAILS, PLATFORM LANDINGS, WALKWAYS, LADDERS, AND SAFETY CLIMB DEVICES SHALL CONFORM WITH CURRENT OSHA STANDARDS.
 - SEE PROJECT SPECIFICATIONS FOR SHOP AND FIELD PAINT REQUIREMENTS.
 - STERILIZE TANK IN ACCORDANCE WITH AWWA C652-92 AND PROJECT SPECIFICATIONS.
 - FOR TANKS LOCATED IN REGIONS WHERE FREEZING CONDITIONS MAY OCCUR CONSIDERATION SHALL BE GIVEN TO OMISSION OF INSIDE TANK & RISER LADDERS.

		REV.	BY:	DATE	REMARKS
BY:	TITLE: ELEVATION DETAILS				
DATE:	DRAWING NO.: DE-1.DWG				